

# DELUGE SYSTEM CHAMBER

Certificate no: DSC-2026-000378

Service date: 21.02.2026

Valid until: 21.02.2027

Result: **Approved**

## Equipment details

Customer: Sjøentreprenøren AS

Producer: DS Bergen AS

Serial no: SC132

Service interval: 12 months

Location: Mjø

Model: Deluge Chamber

Build year: 2024

## NOTE

Deluge fire extinguishing system for chamber SN SC 132, has been tested and inspected.  
System was installed by DS Bergen 2024,

- ✓ 50L SS316 20 Bar water tank, Manufactured 2024 OK, Next hydro test 2034
- ✓ Ball valves internally and externally in chamber OK
- ✓ Panel SN SC 132 OK
- ✓ Nozzles OK
- ✓ Overpressure valves 21.1 bar OK
- ✓ 10L 300bar breathing air cylinder, Hydro test 2023, Next TP 2028
- ✓ Leak test system to Max Working pressure, OK

## Technician

Serviced by: Daniel Kristensen

Signature

*Daniel Kristensen*

