

DELUGE SYSTEM CHAMBER

Certificate no: DSC-2026-000652

Service date: 13.04.2026

Valid until: —

Result: **Rejected**

Equipment details

Customer: Kystarbeid AS

Producer: -

Serial no: 1385

Service interval: 12 months

Location: Chamber Container

Model: Deluge Fire system

Build year: 2010

NOTE

Fire deluge system on Imenco Chamber SN 1385, System is complete for entry and mainlock.

Water tank ALU 20L, DOT and not approved for use in EU/Norway. Need to be replaced with CE or TPED cylinder.

Air drive gas cylinder, 6L SN MS4322UT, Last hydro test 08/2025 - Next hydro 08/2030

Technician

Serviced by: Daniel Kristensen

Signature

